

To,

Angels Sen. Sec. Public School,
Khatauli, Naraingarh Road,
Distt. Ambala.

No. 1996 Dated: - 2/6/2024

Subject: - Building Safety Certificate.

Reference: Your Application received in this office on 20.05.2021.

The School building of Imperial Angels Sen. Sec. Public School, Khatauli, Naraingarh Road, Distt. Ambala has been inspected by the Sub Divisional Engineer, Provincial Sub Division No.6 alongwith JE concerned as reported by him vide his letter No.336 dated 27.05.2021 that proof checked structural drawings from Govt. agency is not provided by your school during visit. The building is visually found structurally safe for running School. The School building Safety Certificate is hereby given upto the period 2021-2022 with the following conditions:


1. Water should not be allowed to stagnate around and on the roof of the building.
2. If building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
3. Institution will be responsible for safety of building from every angle and firefighting equipment should be in functional condition.
4. If the building of this school is to be extended, the same should be first approved from structural Engineer.
5. Proof checked structural drawings should be submitted to this office for record within 01 month after issuing the NOC.
6. Institute shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
7. NOC may be considered as cancelled by this office if the school violates any of the above points.

This is for your information.

DA/ Nil.


Endst.No.

Dated:


Executive Engineer,
Provincial Division No.1,
PWD (B&R), Ambala Cantt.

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.6, PWD B&R, Ambala Cantt for information w.r.t. his office Memo.No.336 dated 27.05.2021.

DA/ Nil.


Executive Engineer,
Provincial Division No.1,